

GOVERNMENT OF RAJASTHAN  
FORM VI  
Rajasthan State Boiler Inspection Department  
CERTIFICATE FOR USE OF A BOILER  
( Regulation 389)

Application Number :2019/2/BRenewal/11135

Registry Number of Boiler:RJ-1550

Type of Boiler:HORIZONTAL MULTITUBLAR SHELL TYPE SMOKE TUBE BOILE

Boiler Rating (m2):44.00

Place and year of manufacture:THERMAX LIMITED PUNE, 2009

Maximum continuous Evaporation (kg/hr):2000.00

Name of Owner:DAIKIN AIR CONDITIONING INDIA PVT. LTD.

Situation of Boiler:SP2-12-SP2-15 & SP-2-24-SP2-27, NEW INDUSTRIAL COMPLEX (NEEMRANA), NEEMR/

Repairs: NA

Remarks: NA

Hydraulically tested on 06/08/2019 to 13.5 kg/cm<sup>2</sup>


I hereby certify that the above described boiler is permitted by me / the Chief Inspector under the provisions of Section 7/8 of the Boilers Act No.V of 1923, to be worked at a Maximum pressure of 10.54 Kg/cm<sup>2</sup> kg/cm<sup>2</sup> for the period from 06/08/2019 to 02/07/2020


The loading of the spg. loaded safety valve is not to exceed max. working pressure allowed. I further certify that the main steam pipe was tested hydraulically to a pressure of last on

Fee: 2400.00 paid on 02/07/2019

Dated at: JAIPUR

Date : 07/08/2019

  
Competent Person  
Ramesh Purohit , Dy. Chief  
Inspector

  
Chief Inspector  
Chief Inspector of Factories  
and Boilers Rajasthan, Jaipur